

A. Testing without load

Visual inspection . . . . . for external leaks  
 Acid level . . . . . should reach to max., see figure 1  
 Acid density . . . . . should be identical in all cells, see figure 2, charge condition see table


**Charge condition**

Charge condition with acid density in kg/dm <sup>3</sup> and at 20 °C	charged	normal tropics	1.28 ± 0.01 1.28 ± 0.01	(okay)
	half charged	normal tropics	1.20 1.16	(recharging required)
	discharged	normal tropics	1.12 1.08	(recharge immediately)
Antifreeze protection	charged	normal tropics	-65 -40	
	half charged	normal tropics	-30 -13	
	discharged	normal tropics	-4 -1	

**1. Checking fluid level**

Should reach to the max. mark, visible on the battery from the outside.

**Note:** If the acid level is corrected, the battery must be recharged until start of gassing before measuring the acid density.



## 54-005 Testing and charging battery

### 2. Testing the acid density

a) 

-	1	2	3	4	5	6
1.28	1.28	1.28	1.28	1.16	1.28	1.28
						+


Short circuit in cell 5

b) 

-	1	2	3	4	5	6
1.28	1.16	1.16	1.28	1.28	1.28	1.28
						+

Leak in the cell wall between cells 2 and 3.

A conductive connection is created by the leaking cell wall and the connector which causes the cells to be discharged.



a = max. 9 mm

1542-8179

### B. Testing under load

Carry out only if no faults were discovered during the test without load.

The minimum voltage should reach a constant value after 10 seconds. Minor deviations are of no consequence. If the voltage drops severely or if the voltage collapses, the battery is defective.

This test is only possible with a uniform acid density of the cells and an acid density of at least 1.24 kg/dm<sup>3</sup>.

Capacity	Ah	44	55	62	66	88	90	92
Load current (approx. 3 times the capacity)	A	135	165	186	200	265	270	276
Minimum voltage after 10 s with acid density	V	9			10			
	kg/dm <sup>3</sup>	1.24	(1.19) <sup>1)</sup>		1.28		(1.23) <sup>1)</sup>	

<sup>1)</sup> Tropics

